

GRIDLINES 1a / 15a / Aa / Bb / Ff and Gg SETTING OUT TBC IN COORDINATION WITH STEEL SUB CONSULTANT STEELWORK DESIGN.

INTERNAL SIPHONIC DRAINAGE OUTLETS SHOWN IN ACCORDANCE WITH SPECIALIST DESIGNERS DETAILS AND INFORMATION.

ALL STRUCTURE SHOWN INDICATIVELY. FOUNDATIONS AND STRUCTURAL DESIGN TO S.E / SUB CONSULTANT DESIGN AND DETAILS.

AIR TEST REQUIREMENT = 2.5 m3/(h.m2) AS SET OUT IN SPECIFICATION.

NO FIRE BOUNDARY CONDITIONS TO UNITS 2 - 3 (SUBJECT TO ASSENT BUILDING CONTROL CONFIRMATION).

ALL INCOMING SERVICES LOCATIONS SHOWN IN LINE WITH MAGROCK INSTRUCTION.

ALL U VALUES TO BE CONFIRMED UPON RECEIPT OF SBEM CALCULATIONS
EXTERNAL WALLS X.XXW/m2K
FLOOR X.XXW/m2K
ROOF X.XXW/m2K
WINDOWS X.XXW/m2K
PERSONNEL DOORS X.XXW/m2K
VEHICLE ACCESS DOORS X.XXW/m2K

